



**Department of Public Works
Milwaukee Water Works**

May 30, 2012
Official Notice No. 12-84-1
Addendum No. 1

Ghassan Korban
Commissioner of Public Works

Preston D. Cole
Director of Operations

Carrie M. Lewis
Superintendent of Water Works

To Whom It May Concern:

Recently you received plans and bid documents for a Water Main Relay in the City of Milwaukee, Official Notice No. 12-84-1.

The contractor shall adhere to the requirements of the following special provision, which was inadvertently left off the construction plan:

Forestry Note

Where curb and gutter removal/replacement is necessary near City street trees on N. 67th St., excavation at the back of curb must be limited to the minimum necessary to set forms. Any tree roots encountered shall be cleanly cut using hand tools. No mechanical sawing of tree root plates abutting the back of curb shall be allowed.

Each bidder shall acknowledge receipt of this addendum in the bid documents.

If you have any questions regarding this, please contact Mr. Mark Scheller at 414-286-2427.

Your interest in this project is greatly appreciated.

Very truly yours,

Dinah G. Gant, P.E.
Chief Design Engineer
Milwaukee Water Works

DGG